



**ΤΕΨΕ**  
**ΨΥΚΤΙΚΑ**

**ΚΩΔΙΚΟΣ ΕΙΔΟΥΣ:**

Technical specifications:

1. Inner tube and outer tube should be cleaned so that ensure the surface of the inner and outer tube to be clean without impurities;
2. All welded place should be well welded. Any defect on small holes and leaks is unacceptable.
3. Heat exchanger is black painted except  $25 \pm 5$ mm cylinder from connections end.
4. Each end connection should be sealed by a plastic cap or welding.
5. Fill 0.05-0.12Mpa nitrogen gas at refrigerant side, the pressure is maintained ;
6. Any non-indicated dimensions and tolerances are subject to GB/T 1804 V degree.
7. Other non-indicated requirements are subject to 《Q/HSS 001-2014 》.

Design data sheet									
Item	Tube side	Shell side							
Medium	Water	R410a							
Design temp °C	65	100	Mark	No.	Modify documents No.	Sign	Date		
Design pressure MPa	1.5	4.2	Design		Standard			Drawing mark	Weight
Insulation	/	/	Check		Authorize			Scale	
Customer drawing No.	/	/	Approve						
Customer item No.	/	/	Process		Date			Total Page	Page

Coaxial Heat Exchanger

Inner tube : Copper  
Outer tube: Steel

**04-290-5855**

SS-0360GT-W

33-3792/418/315/71/2-KØ16

CSSW3603100